

Report #: 840683

Date : 08/04/2006

P.O.Number: Internet

Same as Client


Matrix: Drinking Water

**"Mention EarthTrade Water or Drinking Water Solutions  
& receive a 10% Discount on Lab Tests"**

### Comprehensive Plus Pesticides Scan Report

	<u>Results</u>		<u>Public Drinking Water EPA Limits</u>
<b><u>General Bacteria</u></b>			
Total Coliform	Absent	Animal or Vegetational Bacteria	
Fecal/E. Coli	Absent	Animal Bacteria	
<b><u>General Chemistry</u></b>			
Sodium	16.3 mg/L	20.0 mg/L is Mass. DEP Guideline	250.0 mg/L
Potassium	2.6 mg/L	A Component of Salt	No Limit
Copper	0.02 mg/L	Indicates Plumbing Corrosion	1.30 mg/L
Iron	0.20 mg/L	Brown Stains, Bitter Taste	0.30 mg/L
Manganese	Not Detected	May Cause Laundry Staining	0.05 mg/L
Magnesium	20.1 mg/L	A Component of Hardness	No Limit
Calcium	20.3 mg/L	A Component of Hardness	No Limit
Arsenic	0.005 mg/L	Natural Occurring Element	0.010 mg/L
Lead	Not Detected	A Toxic Metal	0.015 mg/L
pH	7.55 SU	Acid/Basic Determination	6.5 - 8.5 SU
Turbidity	0.10 N.T.U.	Presence of Particles	No Limit
Color	Not Detected	Clarity (0), Discoloration (15)	15.0 C.U.
Odor	Not Detected	Odor due to Contamination	3.0 T.O.N.
Conductivity	530.0 umhos	Electrical Resistance (umhos/cm)	No Limit
T.D.S.	318.0 mg/L	Total Dissolved Minerals Present	500.0 mg/L
Sediment	Absent	Undissolved Solids	Present
Alkalinity	312.5 mg/L	Ability to Neutralize acid	No Limit
Chlorine	Not Detected	A Disinfectant	No Limit
Chloride	12.7 mg/L	A component of salt	250.0 mg/L
Hardness	133.5 mg/L	0 - 75 is considered soft	No Limit
Nitrate	0.3 mg/L	Indicator of Biological Waste	10.0 mg/L
Nitrite	Not Detected	Indicator of Waste	1.0 mg/L
Ammonia	Not Detected	Indicator of Waste	No Limit
Sulfate	1.9 mg/L	A Mineral, Can Cause Odor	250.0 mg/L
<b><u>Radiochemistry</u></b>			
Radon in Water	1137 pCi/L	Massachusetts D.E.P. Guideline	10,000 pCi/L
<b><u>Organic Analysis</u></b>			
Benzene	Not Detected		5.0 ug/L
Bromobenzene	Not Detected		No Limit
Bromochloromethane	Not Detected		No Limit

The integrity of the sample and results are dependent on the quality of sampling. The results apply only to the actual sample test. Environmental Testing and Research Laboratories shall be held harmless from any liability arising out of the use of such results.



Report #: 840683

Date : 08/04/2006

P.O.Number: Internet

Same as Client


Matrix: Drinking Water

## Comprehensive Plus Pesticides Scan Report

	<u>Results</u>	<u>Public Drinking Water EPA Limits</u>
Bromodichloromethane	Not Detected	No Limit
Bromoform	Not Detected	No Limit
Bromomethane	Not Detected	No Limit
n-Butylbenzene	Not Detected	No Limit
sec-Butylbenzene	Not Detected	No Limit
tert-Butylbenzene	Not Detected	No Limit
Carbon-Tetrachloride	Not Detected	5.0
Chlorodibromomethane	Not Detected	No Limit
Chloroethane	Not Detected	No Limit
Chloroform	Not Detected	No Limit
Chloromethane	Not Detected	No Limit
1,2-Chlorotoluene	Not Detected	No Limit
1,4-Chlorotoluene	Not Detected	No Limit
1,2-Dibromo-3-chloropropane	Not Detected	No Limit
Dibromomethane	Not Detected	No Limit
1,2-Dibromomethane	Not Detected	No Limit
1,3-Dichlorobenzene	Not Detected	No Limit
1,2-Dichlorobenzene	Not Detected	600.0 ug/L
1,4-Dichlorobenzene	Not Detected	5.0 ug/L
Dichlorodifluoromethane	Not Detected	No Limit
1,1-Dichloroethane	Not Detected	No Limit
1,2-Dichloroethane	Not Detected	5.0 ug/L
1,1-Dichloroethylene	Not Detected	7.0 ug/L
cis-1,2-Dichloroethene	Not Detected	70.0 ug/L
trans-1,2-dichloroethene	Not Detected	100.0 ug/L
1,2-Dichloropropane	Not Detected	5.0 ug/L
1,3-Dichloropropane	Not Detected	No Limit
2,2-Dichloropropane	Not Detected	No Limit
1,1-Dichloropropene	Not Detected	No Limit
1,3-Dichloropropene	Not Detected	No Limit
trans-1,3-Dichloropropene	Not Detected	No Limit
Ethylbenzene	Not Detected	700.0 ug/L
Fluorotrichloromethane	Not Detected	No Limit
Hexachlorobutadiene	Not Detected	No Limit
Isopropylbenzene	Not Detected	No Limit
Methyl-t-Butyl Ether (MTBE)	Not Detected	70 ug/L
p-Isopropyltoluene	Not Detected	ug/L

Massachusetts DEP Limit

The integrity of the sample and results are dependent on the quality of sampling. The results apply only to the actual sample test. Environmental Testing and Research Laboratories shall be held harmless from any liability arising out of the use of such results.



Report #: 840683

Date : 08/04/2006

P.O.Number: Internet

Same as Client

Matrix: Drinking Water


### Comprehensive Plus Pesticides Scan Report

	<u>Results</u>	<u>Public Drinking Water EPA Limits</u>
Methylene Chloride	Not Detected	5.0
Monochlorobenzene	Not Detected	100.0 ug/L
Napthalene	Not Detected	No Limit
n-Propylbenzene	Not Detected	No Limit
Styrene	Not Detected	100.0 ug/L
1,1,1,2-Tetrachloroethane	Not Detected	No Limit
1,1,2,2-Tetrachloroethane	Not Detected	No Limit
Tetrachloroethylene	Not Detected	5.0 ug/L
Toluene	Not Detected	1000.0 ug/L
1,2,3-Trichlorobenzene	Not Detected	No Limit
1,2,4-Trichlorobenzene	Not Detected	70.0 ug/L
1,1,1-Trichloroethane	Not Detected	200.0 ug/L
1,1,2-Trichloroethane	Not Detected	5.0 ug/L
Trichloroethylene	Not Detected	5.0 ug/l
1,2,3-Trichloropropane	Not Detected	No Limit
1,2,4-Trimethylbenzene	Not Detected	No Limit
1,3,5-Trimethylbenzene	Not Detected	No Limit
Vinyl Chloride	Not Detected	2.0 ug/L
o-Xylene	Not Detected	Total Xylenes 10
m+p Xylenes	Not Detected	Total Xylenes 10

**Pesticides**

Aldrin	Not Detected
A-BHC	Not Detected
B-BHC	Not Detected
C-BHC	Not Detected
D-BHC	Not Detected
Chlordane	Not Detected
4,4'-DDD	Not Detected
4,4'-DDE	Not Detected
4,4'-DDT	Not Detected
Dieldrin	Not Detected
Endosulfan I	Not Detected
Endosulfan II	Not Detected
Endosulfan Sulfate	Not Detected
Endrin	Not Detected
Endrin Aldehyde	Not Detected
Heptachlor	Not Detected

The integrity of the sample and results are dependent on the quality of sampling. The results apply only to the actual sample test. Environmental Testing and Research Laboratories shall be held harmless from any liability arising out of the use of such results.



Report #: 840683

Date : 08/04/2006

P.O.Number: Internet

Same as Client

Matrix: Drinking Water

### Comprehensive Plus Pesticides Scan Report

	<u>Results</u>	<u>Public Drinking Water EPA Limits</u>
Heptachlor Epoxide	Not Detected	
Methoxychlor	Not Detected	
Toxaphene	Not Detected	

The integrity of the sample and results are dependent on the quality of sampling. The results apply only to the actual sample test. Environmental Testing and Research Laboratories shall be held harmless from any liability arising out of the use of such results.